


Box below: Draw or Sketch your Property (regardless of what you are applying for)

- (1) Show Location of: Proposed Construction
- (2) Show / Indicate: North (N) on Plot Plan
- (3) Show Location of (*): (**) Driveway and (**) Frontage Road (Name Frontage Road)
- (4) Show: All Existing Structures on your Property
- (5) Show: (**) Well (W); (**) Septic Tank (ST); (**) Drain Field (DF); (**) Holding Tank (HT) and/or (**) Privy (P)
- (6) Show any (*): (**) Lake; (**) River; (**) Stream/Creek; or (**) Pond
- (7) Show any (*): (**) Wetlands; or (**) Slopes over 20%



Please complete (1) - (7) above (prior to continuing)

Changes in plans must be approved by the Planning & Zoning Dept.

(8) Setbacks: (measured to the closest point)

| Description | Measurement | Description | Measurement |
|---|-------------|--|-------------|
| Setback from the Centerline of Platted Road | 1000 Feet | Setback from the Lake (ordinary high-water mark) | Feet |
| Setback from the Established Right-of-Way | 1000 Feet | Setback from the River, Stream, Creek | 1300 Feet |
| Setback from the North Lot Line | 900 Feet | Setback from the Bank or Bluff | Feet |
| Setback from the South Lot Line | 350 Feet | Setback from Wetland | NONE Feet |
| Setback from the West Lot Line | 1000 Feet | Setback from 20% Slope Area | 000 Feet |
| Setback from the East Lot Line | 1000 Feet | Elevation of Floodplain | Feet |
| Setback to Septic Tank or Holding Tank | 50 Feet | Setback to Well | 25' Feet |
| Setback to Drain Field | 50 Feet | | |
| Setback to Privy (Portable, Composting) | NONE Feet | | |

Prior to the placement or construction of a structure within ten (10) feet of the minimum required setback, the boundary line from which the setback must be measured must be visible from one previously surveyed corner to the other previously surveyed corner or marked by a licensed surveyor at the owner's expense.

Prior to the placement or construction of a structure more than ten (10) feet but less than thirty (30) feet from the minimum required setback, the boundary line from which the setback must be measured must be visible from one previously surveyed corner to the other previously surveyed corner, or verifiable by the Department by use of a corrected compass from a known corner within 500 feet of the proposed site of the structure, or must be marked by a licensed surveyor at the owner's expense.

(9) Stake or Mark Proposed Location(s) of New Construction, Septic Tank (ST), Drain field (DF), Holding Tank (HT), Privy (P), and Well (W).

NOTICE: All Land Use Permits Expire One (1) Year from the Date of Issuance if Construction or Use has not begun.

For The Construction Of New One & Two Family Dwellings: ALL Municipalities Are Required To Enforce The Uniform Dwelling Code. The local Town, Village, City, State or Federal agencies may also require permits.

Issuance Information (County Use Only) Sanitary Number: 367342 # of bedrooms: 3 Sanitary Date: 8-25-08
 Permit Denied (Date): Reason for Denial: 7-15-14

Permit #: 14-0216 Permit Date: 7-05-14

Is Parcel a Sub-Standard Lot Yes No
 Is Parcel in Common Ownership Yes No
 Is Structure Non-Conforming Yes No

Granted by Variance (B.O.A.) Yes No Case #: _____

Was Parcel Legally Created Yes No
 Was Proposed Building Site Delineated Yes No

Inspection Record: Rebuilding house that burned down
 Special Use Class A previously approved

Date of Inspection: 6-3-14 Inspected by: JERRY BORK-MURPHY

Conditions/Town, Committee or Board Conditions Attached? Yes No - If No they need to be attached
 FIRE DRAINAGE TO ATANY ELECTRICAL FOR HOLDING TANK SHALL BE REPAIRERS
 PRIOR TO OCCUPATION. ALL WEATHER ROPS W/IN 25' FROM HOLDING TANK
 SHALL BE MAINTAINED. GREEN
 UDC PERMIT + INSPECTION SHALL BE OBTAINED BY OWNER.

Signature of Inspector: _____ Date of Approval: 6-5-14

Hold For Sanitary: Hold For TBA: Hold For Affidavit: Hold For Fees: